

TCEP No.: 097-040-16
LPS No.: 8465

ADDENDUM NO. 1

The Architect/ Engineer issues this addendum, applicable to the above named project, to all known Contractors before receipt of proposal.

This addendum includes Item Number 1-1 thru 1-3. This addendum item shall be fully incorporated into the Bidding/Contract Documents and have the same force and effect as though originally included.

The Bidder shall acknowledge receipt of this Addendum No. 1 on the Bid Proposal Form in the place provided.

GENERAL

Item 1-1: Section 00 42 00, Proposal Form

The following sentences in the Bid Proposal Form have been modified to read:

Pole bases and conduit shall be brought to a state of substantial completion by August 12th, 2016. The undersigned proposes to bring the entire project to a state of Substantial Completion by **October 30, 2016**

ELECTRICAL

Specifications

Item 1-2: Section 26 51 00, Lighting Fixtures

The following lighting fixtures have been reviewed in accordance with paragraph 2, and are included in the Contract Documents for bidding purposes. All fixtures, lamps, and ballasts are required to meet the specification requirements regardless of prior approval. Prior approval does not waive any requirements indicated on the drawings or the specifications. Some fluorescent fixtures require dimming or multiple levels of switching. The required number and types of ballasts shall be provided to meet the switching requirements shown on the drawings.

<u>Type</u>	<u>Manufacturer and Catalog Number</u>	
A	McGraw-Edison	GLEON-AE-06-LED-E1-T4FT-AP-530-LCF-HSS
A pole	McGraw-Edison	RSS-5-M-25-S-V-N-1

Drawings

Item 1-3: Sheet E0.01 – Electrical Site Utilities Plan

The pole fixture located on the south side of the lot shall be moved approximately 3' to the northwest, but not to impede into the adjacent parking spaces. Orient fixture as to reduce light trespass on the adjacent residential parking lot.

END OF ADDENDUM NO. 1