



## ADDENDUM #001

DATE: JULY 28, 2016

6912 NORTH 97TH CIRCLE, SUITE 1 • OMAHA, NEBRASKA 68122 • 402.391.3999  
WEB: WWW.JACKSON-JACKSONASSOCIATES.COM • EMAIL: JACKSON-JACKSON@JJAARCHITECTS.COM

JACKSON  
JACKSON  
& ASSOCIATES, INC.

PROJECT:  
NEBRASKA LAW ENFORCEMENT TRAINING  
CENTER - BALCONY MODIFICATIONS  
3600 N. ACADEMY ROAD,  
GRAND ISLAND NE 68801

JJA PROJECT:  
NUMBER 3474  
DRAWINGS & SPECIFICATIONS  
DATED: 7/15/16

**The Drawings and Specifications for the above referenced project are hereby amended and the following changes shall be made part of the Contract Documents.**

### ARCHITECTURAL

**ITEM #1**      Refer to the attached Sign-In Sheet for the Pre-Bid Walkthrough occurring on July 26, 2015.

**ITEM #2**      Refer to the Alternate #1 Drawings, Sheets, A2.1A – Skylight Infill Section and A2.2A – Skylight Infill Section.

- A. Refer to the sheet note that reads "60 MIL. FULLY ADHERED EPDM MEMBRANE".  
Revise this note to read "90 MIL. FULLY ADHERED EPDM MEMBRANE".

