



Innovative Design in Architecture

BIDDERS BULLETIN

PROJECT: Wallace Public Schools
Classroom & Shop Addition
Wallace, Nebraska

BULLETIN NUMBER

BB-3

ISSUED BY:

Grant Creager

PROJECT #: 16-1026

DATE ISSUED: October 28th, 2016

This bulletin is issued by the Architect to all known bidders before receipt of proposals, for the purpose of explaining, interpreting, or modifying the original plans and specifications. When enumerated by the bidder upon the proposal sheet, the information or instructions given hereon will be equally binding upon all parties as if included in the original plans and specifications.

BIDDER MUST ENTER THE NUMBER OF THIS BULLETIN ON HIS PROPOSAL SHEET

GENERAL INFORMATION

~~

~~

THE FOLLOWING ITEMS ARE APPLICABLE TO THE SPECIFICATIONS

THE FOLLOWING ITEMS ARE APPLICABLE TO THE DRAWINGS:

BB-3, Item #1: Door, Window, Frame and Schedule A-601

*Door and Frame Schedule, Door 107, Width to be **Pair 3'-0"** in lieu of 3'-0"

END OF BB-3, See attachments. Mechanical & Electrical comments attached separately.

Wallace Public Schools
 Classroom & Shop Building Addition
 Bidder's Bulletin #3
 October 28th, 2016

Addendum 3



www.specializedeng.com

Date: 10/28/2016

Project Name: Wallace Public Schools - Shop Replacement

Project #: 16071

Mechanical Drawing Items:

MD1. Sheet M401 – Mechanical Schedules

A. Refer to the Fan Schedule.

1. Marks EF-2, EF-4, EF-7, and SF-1: Remove remark (5). These fans shall not be required to have spark resistant construction with explosion proof motors.
 2. Marks EF-2, EF-3, EF-4, and EF-7: Add remark (3). Provide motorized backdraft damper interlocked with fan operation.
-

Submitted By: Jeremy Klima, Ben Schmitt